

DRIVEWAYS

No new private driveways, at the sidewalk crossing, shall be constructed of anything other than concrete and meeting all of the specifications of this section. They shall have a minimum thickness of six (6) inches. A curb extending eighteen (18) inches below the gutter line shall be constructed along the street face at all driveways. Provided, however, that private driveways less than twenty (20) feet in width shall be no less than thirteen (13) inches below the gutter line; that Council may refuse to authorize the issuance of permit for construction of driveways across sidewalks, when, in its discretion, the construction of such driveways would constitute a hazard to and imperil the safety of pedestrians or vehicular traffic. The curb shall not be depressed below one (1) inch above the gutter line.

No public service curb or sidewalk boxes for access to underground facilities/utilities shall be left below or above the sidewalk level. The property owner or the owner of the same shall bring them to the grade of the new walk.